

Day	pH	Alk	Phos	Other	Y/N
1	7.43				
2	7.51		.24		N
3	7.52				
4	7.53				
5	7.44		.25		N
6	7.41				
7	7.37				
8	7.45				
9	7.39		.25		N
10	7.40				
11	7.42				
12	7.43		.81		Y
13	7.45				
14	7.43		.78		Y
15	7.41				
16	7.43		.26		N
17	7.44				
18	7.44				
19	7.39		.29		N
20	7.45				
21	7.42		.54		N
22	7.41				
23	7.40		.65		Y
24	7.34				
25	7.41				
26	7.35		.19		N
27	7.36				
28	7.35		.94		Y
29	7.40				
30	7.40		.76		Y
31					

<<Have minimums been met for this day?

County: Polk      Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100537**  
**MONMOUTH, CITY OF**

**Sample period:** April 2021  
*Month/Year*

**Number of excursions during this month:** N/A  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference \_\_\_\_\_

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0

PO4 0.6 (Orthophosphate)

**Print Name:** Matthew Johnson  
**Signature:**   
**Date & Phone#:** 503-838-2173      5/3/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 7