

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.36				Y
4					
5					
6					
7					
8					
9					
10	7.20				Y
11					
12					
13					
14					
15					
16					
17	7.32				Y
18					
19					
20					
21					
22					
23					
24	7.39				Y
25					
26					
27					
28					
29					
30					
31	7.25				Y

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100538**

**LUCKIAMUTE DOMESTIC WATER COOP**

Sample period: OCTOBER 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

Print Name: Charles Prouty

Signature: Charles Prouty

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**