

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.32				Y
6					
7					
8					
9					
10					
11					
12	7.24				Y
13					
14					
15					
16					
17					
18					
19	7.40				Y
20					
21					
22					
23					
24					
25					
26	7.23				Y
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Polk

Agency: POLK COUNTY

ENTRY POINT

EP-A

PWS ID 4100538

LUCKIAMUTE DOMESTIC WATER COOP

Sample period: AUGUST 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Charles Prouty

Signature: Charles Prouty

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0