

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.62				Y
3					
4					
5					
6					
7					
8					
9	7.33				Y
10					
11					
12					
13					
14					
15					
16	7.69				Y
17					
18					
19					
20					
21					
22					
23	7.55				Y
24					
25					
26					
27					
28					
29					
30	7.64				Y
31					

<<Have
minimums
been met for
this day?

County: Polk Agency: POLK COUNTY

ENTRY POINT

EP-A

PWS ID 4100538

LUCKIAMUTE DOMESTIC WATER COOP

Sample period: December 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

Print Name: Charles Prouty

Signature: Charles Prouty

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's**