

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.68				Y
5					
6					
7					
8	7.52				Y
9					
10					
11	8.44				Y
12					
13					
14					
15					
16	7.48				Y
17					
18					
19	7.41				Y
20					
21					
22					
23					
24					
25	7.20				Y
26					
27					
28					
29					
30	7.08				Y
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

ENTRY POINT

EP-B

PWS ID 4100538

LUCKIAMUTE DOMESTIC WATER COOP

Sample period: MARCH 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: CAROL CLARK

Signature: _____

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**