

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.31				Y
2					
3					
4					
5					
6	7.45				Y
7					
8					
9	7.67				Y
10					
11					
12					
13					
14	7.97				Y
15					
16					
17					
18					
19	8.04				Y
20					
21	7.94				Y
22					
23					
24					
25					
26	7.70				Y
27					
28					
29					
30	7.36				Y
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4100538**

**LUCKIAMUTE DOMESTIC WATER COOP**

Sample period:                     JULY 2021                      
Month/Year

Number of excursions during this month:   0  

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0

Print Name:                     CAROL CLARK                    

Signature:                     Carol Clark                    

Date & Phone#:                     503-838-2075                    

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0