

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.30				Y
2					
3					
4					
5					
6					
7	7.24				Y
8					
9					
10					
11					
12					
13					
14	7.41				Y
15					
16					
17					
18					
19					
20					
21					
22	7.78				Y
23					
24					
25					
26					
27					
28					
29	7.98				Y
30					
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

ENTRY POINT

EP-B

PWS ID 4100538

LUCKIAMUTE DOMESTIC WATER COOP

Sample period: JUNE 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Print Name: CAROL CLARK

Signature: *Carol Clark*

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0