

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.66				Y
4					
5					
6					
7					
8					
9					
10	7.33				Y
11					
12					
13					
14					
15					
16					
17	7.37				Y
18					
19					
20					
21					
22					
23					
24	7.53				Y
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Polk

Agency: POLK COUNTY

ENTRY POINT

EP-B 

PWS ID 4100538

LUCKIAMUTE DOMESTIC WATER COOP

Sample period: APRIL 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Print Name: Charles Prouty

Signature: Charles Prouty

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of
sampling period