

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.58				Y
3					
4					
5					
6					
7					
8	7.37				Y
9					
10					
11					
12					
13					
14					
15					
16					
17	7.91				Y
18					
19					
20					
21					
22					
23	8.46				Y
24					
25					
26					
27					
28					
29					
30	7.52				Y
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100538**

**LUCKIAMUTE DOMESTIC WATER COOP**

Sample period:         JUNE 2022          
Month/Year

Number of excursions during this month:   0  

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

Print Name:         Carol Clark        

Signature:         Carol Clark        

Date & Phone#:         503-838-2075        

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**