

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.53				Y
2					
3					
4					
5					
6					
7					
8					
9					
10	7.57				Y
11					
12					
13					
14	7.23				Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.89				Y
26					
27					
28					
29					
30	7.39				Y
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4100538**

**LUCKIAMUTE DOMESTIC WATER COOP**

Sample period: MARCH 2022  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0

Print Name: CAROL CLARK

Signature: *Carol Clark*

Date & Phone#: 503-838-2075

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0