

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.90				Y
3					
4					
5					
6	7.09				Y
7					
8					
9					
10					
11					
12	8.20				Y
13					
14					
15					
16					
17					
18	7.28				Y
19					
20					
21					
22					
23					
24					
25					
26	7.07				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Polk Agency: POLK COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4100538**

**LUCKIAMUTE DOMESTIC WATER COOP**

Sample period:           MAY 2022            
Month/Year

Number of excursions during this month:   0  

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.0

Print Name:           CAROL CLARK          

Signature:           *Carol Clark*          

Date & Phone#:           503-838-2075          

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0