

Day	pH	Alk	Phos	Other	Y/N
1	7.8	22.3			Y
2	7.9	21.6			Y
3	7.8				Y
4	7.8	20.4			Y
5	7.9	20.6			Y
6					
7					
8	7.9				Y
9	7.9	20.9			Y
10					
11	7.9	20.0			Y
12	7.8	26.0			Y
13					
14					
15	7.9	28.7			Y
16	7.9				Y
17	7.8				Y
18					
19	7.8	30.3			Y
20					
21					
22	7.8	35.6			Y
23					
24	7.8				Y
25	7.8	37.8			Y
26	7.8				Y
27					
28					
29	7.9				Y
30					
31	7.8	36.7			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: March 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Charles Scholz

Signature: 

Date: 4/13/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2