

| Day | pH  | Alk  | Phos | Other | Y/N |
|-----|-----|------|------|-------|-----|
| 1   |     |      |      |       |     |
| 2   |     |      |      |       |     |
| 3   | 7.8 | 40.8 |      |       | Y   |
| 4   | 7.7 |      |      |       | Y   |
| 5   | 7.8 | 39.3 |      |       | Y   |
| 6   | 7.8 |      |      |       | Y   |
| 7   |     |      |      |       |     |
| 8   |     |      |      |       |     |
| 9   |     |      |      |       |     |
| 10  | 7.9 | 35.6 |      |       | Y   |
| 11  | 7.8 |      |      |       | Y   |
| 12  | 7.8 | 36.7 |      |       | Y   |
| 13  | 7.9 |      |      |       | Y   |
| 14  | 7.8 | 33.9 |      |       | Y   |
| 15  |     |      |      |       |     |
| 16  |     |      |      |       |     |
| 17  | 8.0 |      |      |       | Y   |
| 18  | 7.8 | 34.3 |      |       | Y   |
| 19  | 7.8 |      |      |       | Y   |
| 20  | 7.8 |      |      |       | Y   |
| 21  | 7.7 | 31.8 |      |       | Y   |
| 22  |     |      |      |       | Y   |
| 23  |     |      |      |       | Y   |
| 24  | 7.6 | 30.6 |      |       | Y   |
| 25  | 7.8 |      |      |       | Y   |
| 26  | 7.7 |      |      |       | Y   |
| 27  | 7.7 | 32.1 |      |       | Y   |
| 28  | 7.7 |      |      |       | Y   |
| 29  |     |      |      |       |     |
| 30  |     |      |      |       |     |
| 31  |     |      |      |       |     |

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: May 2021

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**


pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Charles Scholz

Signature: 

Date: 6-10-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's