

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	7.9	27.8			Y
4					
5					
6	7.8	25.3			Y
7	7.9				Y
8	7.7				Y
9	7.8	22.1			Y
10	7.7				Y
11					
12					
13	7.7	26.4			Y
14	7.9				Y
15	8.0				Y
16					
17	7.9	23.2			Y
18					
19					
20					
21	7.8				Y
22	7.8	22.1			Y
23	8.0				Y
24	7.7	20.7			Y
25					
26					
27	7.7				Y
28	8.0	22.5			Y
29	7.8				Y
30	8.0	21.5			Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: June 2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Charles Scholz

Signature: *Charles Scholz*

Date: 7-7-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's