

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9	36.1			Y
2	8.2				Y
3	7.8				Y
4	7.8				Y
5	8.0				Y
6					
7					
8	8.0				Y
9	7.9	37.9			Y
10					
11	7.9	38.4			Y
12	8.0				Y
13					
14					
15	7.9				Y
16	7.9	35.5			Y
17	7.6				Y
18	7.9				Y
19	7.7				Y
20					
21					
22	7.7	36.8			Y
23	8.0				Y
24	8.1				Y
25	8.1	37.3			Y
26	8.6				Y
27					
28					
29					
30	7.7	36.2			Y
31	7.7				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: August 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

Print Name: Charles Scholz

Signature:

Date: 9/9/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's