

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6				Y
4	7.9				Y
5	7.8	30.1			Y
6	7.8				Y
7	7.7				Y
8					
9					
10	7.8				Y
11	7.6				Y
12	7.9	28.5			Y
13	7.8				Y
14	7.7				Y
15					
16					
17	7.6				Y
18	7.9				Y
19	7.6	27.4			Y
20	7.9				Y
21	7.8				Y
22					
23					
24	8.0				Y
25	7.9				Y
26	8.0	26.8			Y
27	7.8				Y
28					
29					
30					
31	7.8				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00540

System Name: City of Monroe

Entry Point: EP-B

Sample Period: October 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Charles Scholz

Signature:

Date: 11-4-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0