

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.7				Y
3					
4					
5	8.0	24.2			Y
6	7.8				Y
7	7.7				Y
8	7.7				Y
9	7.8				Y
10					
11					
12	7.8				Y
13	7.9				Y
14	7.8	26.3			Y
15	7.8				Y
16	7.8				Y
17					
18					
19	7.8				Y
20	7.8				Y
21	8.0	25.1			Y
22	7.9				Y
23					
24					
25					
26					
27	7.6				Y
28	7.7				Y
29	7.9	23.4			Y
30	7.7				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: December 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.8"/>	
Alk	<input type="text" value="24.2"/>	(Alkalinity)
PO4	<input type="text" value="26.3"/>	(Orthophosphate)
Other	<input type="text" value=""/>	()

Print Name: Charles Scholz

Signature:

Date: 01-09-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's