

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.9				Y
4	7.6				Y
5	7.7				Y
6	7.6				Y
7					
8					
9	7.8				Y
10	8.0				Y
11	7.8				Y
12	7.8				Y
13	7.7				Y
14					
15					
16					
17	7.7				Y
18	7.9				Y
19	7.9				Y
20	7.8				Y
21					
22					
23	8.0				Y
24	7.9				Y
25	7.9				Y
26	8.0				Y
27	7.8				Y
28					
29					
30	7.9				Y
31	7.9				Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: January 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Charles Scholz

Signature: 

Date: 2-3-2023

Send to DWP within 10 days after end of sampling period