

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				Y
2	8.1				Y
3	7.9				Y
4	8.0				Y
5	8.0				Y
6	8.0				Y
7					
8	8.1				Y
9	8.0				Y
10	7.9				Y
11	8.0				Y
12	8.0				Y
13					
14					
15	7.7				Y
16	7.7				Y
17	7.8				Y
18	7.7				Y
19	7.8				Y
20					
21					
22	7.8				Y
23	7.8				Y
24	8.0				Y
25	7.9				Y
26	7.8				Y
27					
28	7.8				Y
29					
30	7.7				Y
31	7.6				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 5 4 0

System Name: City of Monroe

Entry Point: EP-B

Sample Period: May 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: Charles Scholz

Signature:

Date: 6-8-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0