

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	8.0				Y
3	8.0				Y
4					
5	7.8				Y
6	7.7				Y
7	7.9				Y
8					
9					
10	7.7				Y
11	7.8				Y
12	7.7				Y
13	8.0				Y
14	7.8				Y
15	7.9				Y
16					
17	7.7				Y
18	7.9				Y
19	7.9				Y
20	8.1				Y
21	7.8				Y
22					
23					
24	8.1				Y
25	7.9				Y
26	7.8				Y
27	7.8				Y
28	7.8				Y
29					
30					
31	7.9				Y

<<Have

minimums
 been met for
 this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: July 2023
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Charles Scholz

Signature: 

Date: 8-7-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's