

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.9 |     |      |       | Y   |
| 2   | 8.2 |     |      |       | Y   |
| 3   | 8.0 |     |      |       | Y   |
| 4   | 7.9 |     |      |       | Y   |
| 5   | 8.0 |     |      |       | Y   |
| 6   | 8.0 |     |      |       | Y   |
| 7   |     |     |      |       |     |
| 8   |     |     |      |       |     |
| 9   | 8.1 |     |      |       | Y   |
| 10  | 8.0 |     |      |       | Y   |
| 11  | 8.0 |     |      |       | Y   |
| 12  | 8.0 |     |      |       | Y   |
| 13  | 8.0 |     |      |       | Y   |
| 14  |     |     |      |       |     |
| 15  |     |     |      |       |     |
| 16  | 7.8 |     |      |       | Y   |
| 17  | 8.0 |     |      |       | Y   |
| 18  | 7.9 |     |      |       | Y   |
| 19  | 7.4 |     |      |       | Y   |
| 20  | 7.7 |     |      |       | Y   |
| 21  | 7.7 |     |      |       | Y   |
| 22  |     |     |      |       |     |
| 23  | 8.1 |     |      |       | Y   |
| 24  | 8.0 |     |      |       | Y   |
| 25  |     |     |      |       |     |
| 26  | 8.1 |     |      |       | Y   |
| 27  | 8.1 |     |      |       | Y   |
| 28  | 8.0 |     |      |       | Y   |
| 29  |     |     |      |       |     |
| 30  | 8.0 |     |      |       | Y   |
| 31  | 8.0 |     |      |       | Y   |

(No = N = Excursion) Total N's 0

<<Have

minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 00540

System Name: City of Monroe

Entry Point: EP-B

Sample Period: December 2024  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH 8.0  
Alk 100 (Alkalinity)  
PO4 0.5 (Orthophosphate)  
Other   ( )

Print Name: Charles Scholz

Signature: 

Date: 1/10/25

Send to DWP within 10 days after end of  
sampling period