

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.1				Y
3	8.0				Y
4					
5					
6	8.0				Y
7	8.0				Y
8	8.1				Y
9	8.1				Y
10	8.1				Y
11					
12					
13	8.1				Y
14	8.1				Y
15	8.2				Y
16	8.1				Y
17	8.0				Y
18					
19					
20					
21	8.1				Y
22	8.0				Y
23	8.1				Y
24	8.1				Y
25					
26					
27	8.1				Y
28	8.1				Y
29	8.1				Y
30	8.0				Y
31	8.1				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: City of Monroe

Entry Point: EP-B

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH (Alkalinity)
Alk (Orthophosphate)
PO4 ()
Other

Print Name: Charles Scholz

Signature: [Signature]

Date: 2-5-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's