

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   | 8.2  |     |      |       | Y   |
| 2   |      |     |      |       | Y   |
| 3   |      |     |      |       |     |
| 4   | 8.0  |     |      |       | Y   |
| 5   | 8.2  |     |      |       | Y   |
| 6   | 7.95 |     |      |       | Y   |
| 7   | 7.94 |     |      |       | Y   |
| 8   | 7.90 |     |      |       | Y   |
| 9   |      |     |      |       |     |
| 10  |      |     |      |       |     |
| 11  | 8.09 |     |      |       | Y   |
| 12  | 8.20 | 25  |      |       | Y   |
| 13  | 8.07 |     |      |       | Y   |
| 14  | 8.18 |     |      |       | Y   |
| 15  | 8.16 |     |      |       | Y   |
| 16  |      |     |      |       |     |
| 17  |      |     |      |       |     |
| 18  | 8.09 |     |      |       | Y   |
| 19  | 8.12 |     |      |       | Y   |
| 20  | 7.90 |     |      |       | Y   |
| 21  | 8.11 |     |      |       | Y   |
| 22  | 8.10 |     |      |       | Y   |
| 23  |      |     |      |       |     |
| 24  |      |     |      |       |     |
| 25  | 8.05 |     |      |       | Y   |
| 26  | 7.96 |     |      |       | Y   |
| 27  | 8.11 |     |      |       | Y   |
| 28  | 7.95 |     |      |       | Y   |
| 29  | 8.10 |     |      |       | Y   |
| 30  |      |     |      |       |     |
| 31  |      |     |      |       |     |

(No = N = Excursion) **Total N's**

**0**

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

0 0 5 4 0

System Name: City of Monroe

Entry Point: EP-B

Sample Period: August 2025

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH  (Alkalinity)  
Alk   
PO4  (Orthophosphate)  
Other  (\_\_\_\_\_)

Print Name: Chuck Scholz

Signature: 

Date: 9/10/25

Send to DWP within 10 days after end of  
sampling period.