

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.9				Y
3	8.1				Y
4	7.8				Y
5	7.9				Y
6					
7					
8	8.0				Y
9	8.1				Y
10	7.9				Y
11	8.0	25			Y
12	7.8				Y
13					
14					
15	8.0				Y
16	8.0				Y
17	7.9				Y
18					
19	7.9				Y
20					
21					
22	7.9				Y
23	8.2				Y
24	7.9				Y
25	7.9				Y
26	7.9				Y
27					
28					
29	8.0				Y
30	7.9				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	5	4	0
---	---	---	---	---

System Name: City of Monroe

Entry Point: EP-B

Sample Period: September 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH (Alkalinity)
Alk
PO4 (Orthophosphate)
Other ()

Print Name: Chuck Scholz

Signature: 

Date: 10/9/2025

Send to DWP within 10 days after end of sampling period.