

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
07	7.82		1.3		Y
21	7.85		1.3		Y

<< Have  
minimums  
been met for  
this day?

County: Clackamas Agency: C

**ENTRY POINT  
A**

**PWS ID 4100547**

**MULINO WATER DISTRICT**

Sample period: 12/2023  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

-Reference -

**Minimum Water Quality  
Parameter(s) as set by State:**

pH



Print Name: MARVIN TROGDEN

Signature: [Handwritten Signature]

Date: 12/28/2023

(No = N = Excursion) Total N's

Send to DWP within 10 days after end of sampling period  
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp