



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
10	7.85		13		Y
24	7.84		13		Y

<<Have minimums been met for this day?

County: Clackamas Agency: C

ENTRY POINT

A

PWS ID 4100547

MULINO WATER DISTRICT

Sample period: 07/2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.3



Print Name: MARVIN TROGDON
Signature: *Marvin Trogdon*
Date: 7/31/2024

(No = N = Excursion) Total N's 0