

Day	pH	Alk	Phos	Sili	Y/N
10	7.85		1.3		Y
24	7.88		1.3		Y

<<Have
 minimums
 been met for
 this day?

County: Clackamas Agency: C
ENTRY POINT
A
PWS ID 4100547
MULINO WATER DISTRICT
 Sample period: 10/2024
 Month/Year

Number of excursions during this month: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3



Print Name: MARIN FROEDAN
 Signature: [Signature]
 Date: 10/31/2024

(No = N = Excursion) Total N's 0