

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
07	7.89		1.3		Y
21	7.88		1.3		Y

<<Have
minimums
been met for
this day?

County: Clackamas Agency: C
**ENTRY POINT
B**
PWS ID 4100547
MULINO WATER DISTRICT
Sample period: 01/2021
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
Minimum Water Quality
Parameter(s) as set by State:
pH 7.3

Print Name: MARVIN TROGDON
Signature: *M. Trogdon*
Date: 1/27/2021

0 = N = Excursion) Total N's 0