

Lead & Copper Rule Corrosion Control


Day	pH	Alk	Phos	Sili	Y/N
11	7.95		1.3		Y
25	7.90		1.3		Y

<<Have minimums been met for this day?

County: Clackamas Agency: C
**ENTRY POINT
 B**
 PWS ID 4100547
 MULINO WATER DISTRICT
 Sample period: 05/2021
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality
 Parameter(s) as set by State:
 pH 7.3


Print Name: MARVIN TROBDDON
 Signature: *[Handwritten Signature]*
 Date: 5/26/2021

(Y = N = Excursion) Total N's: 0