



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
11	7.92		1.3		Y
25	7.95		1.3		Y

<<Have minimums been met for this day?

County: Clackamas Agency: C

ENTRY POINT  
B

PWS ID 4100547

MULINO WATER DISTRICT

Sample period: 06/2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH 7.3



Print Name: MARVIN TROGDON  
Signature: [Handwritten Signature]  
Date: 6/30/2021

0 = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period  
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone: (503) 731-4381 Website: [www.ohd.hr.state.or.us/dwp](http://www.ohd.hr.state.or.us/dwp)