Water Quality Parameter Monitoring Form

DHS oregon department of human services

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
07	7.76		1.3		Y
21	7.75		1.3		Y

<<Have minimums been met for this day?

(No = N = Excursion) **Total N's** 0

County: Clackamas Agency: C

ENTRY POINT

B

PWS ID 4100547

MULINO WATER DISTRICT

Sample period: 04/2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

Print Name: Marvin Trogdon
Signature: Marv Trogdon
Date: 5/1/2023

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp