

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
06	7.78		1.3		Y
20	7.75		1.3		Y

<<Have minimums been met for this day?

County: Clackamas Agency: C

ENTRY POINT

B

PWS ID 4100547

MULINO WATER DISTRICT

Sample period: 02/2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.3



Print Name: MARVIN TROGDON

Signature: Marvin Trogon

Date: 02/23/2024

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp