

Lead & Copper Rule Corrosion Control

[illegible]

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: C

ENTRY POINT

B

PWS ID 4100547

MULINO WATER DISTRICT

Sample period:

05/2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Print Name: MARVIN TROON

Signature: Marcus Trope

Date: 5/29/2025

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp