



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.5	52.0	1.98		Y
2	----	----	----		----
3	----	----	----		----
4	8.7	56.0	2.19		Y
5	8.7	----	2.07		Y
6	8.6	54.0	2.12		Y
7	8.4	----	1.64		Y
8	8.4	53.0	1.76		Y
9	----	----	----		----
10	----	----	----		----
11	8.4	54.0	1.94		Y
12	8.7	----	1.98		Y
13	8.8	58.0	1.99		Y
14	8.9	----	1.95		Y
15	8.8	57.0	1.96		Y
16	----	----	----		----
17	----	----	----		----
18	8.5	52.0	1.98		Y
19	8.2	----	1.97		Y
20	8.2	51.0	1.89		Y
21	8.2	----	1.84		Y
22	8.2	50.0	1.87		Y
23	----	----	----		----
24	----	----	----		----
25	8.1	49.0	1.96		Y
26	8.1	----	1.94		Y
27	8.0	48.0	1.91		Y
28	8.0	----	1.96		Y
29	8.0	49.0	1.98		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: March 2024
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>()</i>

Print Name: Ryan A. Sherman

Signature: 

Date: April 1, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2