



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	7.9	49.0	1.96		Y
2	7.9	-----	1.99		Y
3	8.1	33.0	1.67		Y
4	8.1	-----	1.76		Y
5	8.2	37.0	1.91		Y
6	-----	-----	-----		-----
7	-----	-----	-----		-----
8	8.2	39.0	1.60		Y
9	8.3	38.0	1.54		Y
10	8.1	39.0	1.40		Y
11	8.1	40.0	1.49		Y
12	8.1	41.0	1.52		Y
13	-----	-----	-----		-----
14	-----	-----	-----		-----
15	8.1	40.0	1.54		Y
16	8.0	-----	1.37		Y
17	7.7	51.0	1.41		Y
18	7.8	-----	1.46		Y
19	7.8	50.0	1.49		Y
20	-----	-----	-----		-----
21	-----	-----	-----		-----
22	7.9	50.0	1.53		Y
23	7.9	-----	1.56		Y
24	7.9	49.0	1.58		Y
25	7.9	-----	1.35		Y
26	7.9	50.0	1.44		Y
27	-----	-----	-----		-----
28	-----	-----	-----		-----
29	7.9	27.0	1.79		Y
30	8.5	-----	1.47		Y
31	-----	-----	-----		-----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: April 2024
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: May 1, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2