



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	7.7	29.0	1.52		Y
2	7.8	----	1.63		Y
3	7.9	35.0	1.79		Y
4	----	----	----		----
5	----	----	----		----
6	8.2	42.0	1.58		Y
7	8.2	----	1.61		Y
8	8.3	46.0	1.68		Y
9	8.4	----	1.76		Y
10	8.5	49.0	1.92		Y
11	----	----	----		----
12	----	----	----		----
13	8.0	38.0	1.86		Y
14	7.9	----	1.93		Y
15	7.8	41.0	1.71		Y
16	----	----	----		----
17	7.9	39.0	1.80		Y
18	----	----	----		----
19	----	----	----		----
20	7.9	39.0	1.86		Y
21	7.8	----	2.20		Y
22	----	----	----		----
23	7.8	49.0	1.34		Y
24	7.8	53.0	1.39		Y
25	----	----	----		----
26	----	----	----		----
27	7.9	54.0	1.44		Y
28	7.8	----	1.47		Y
29	7.9	55.0	1.54		Y
30	7.8	----	1.55		Y
31	7.8	56.0	1.79		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: May 2024
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>(_____)</i>

Print Name: Ryan A. Sherman

Signature: 

Date: June 3, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>