



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	----	----	----		----
3	7.7	52.0	1.31		Y
4	7.7	----	1.49		Y
5	7.7	53.0	1.46		Y
6	----	----	----		----
7	7.7	33.0	1.58		Y
8	----	----	----		----
9	----	----	----		----
10	7.7	27.0	1.54		Y
11	7.7	----	1.56		Y
12	7.7	43.0	1.56		Y
13	7.9	----	1.37		Y
14	7.9	27.0	2.20		Y
15	----	----	----		----
16	----	----	----		----
17	8.0	48.0	1.39		Y
18	8.1	----	1.36		Y
19	----	----	----		----
20	8.2	49.0	1.39		Y
21	8.2	47.0	1.52		Y
22	----	----	----		----
23	----	----	----		----
24	8.3	50.0	1.68		Y
25	8.3	----	1.76		Y
26	8.3	49.0	1.74		Y
27	8.2	----	1.79		Y
28	8.1	44.0	1.31		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: June 2024
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature:

Date: July 1, 2024