



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.3	65.0	1.45		Y
2	8.2	----	1.48		Y
3	8.2	62.0	1.44		Y
4	8.2	----	1.41		Y
5	8.3	61.0	1.47		Y
6	----	----	----		----
7	----	----	----		----
8	8.4	60.0	1.67		Y
9	8.5	----	1.77		Y
10	8.6	58.0	1.74		Y
11	8.6	----	1.70		Y
12	8.5	50.0	2.20		Y
13	----	----	----		----
14	----	----	----		----
15	8.6	63.0	2.20		Y
16	8.5	----	2.20		Y
17	8.5	62.0	2.15		Y
18	8.5	----	2.21		Y
19	8.7	67.0	1.39		Y
20	----	----	----		----
21	----	----	----		----
22	8.6	72.0	1.40		Y
23	8.6	----	1.44		Y
24	8.5	70.0	1.50		Y
25	8.5	----	2.20		Y
26	8.5	70.0	2.20		Y
27	----	----	----		----
28	----	----	----		----
29	8.4	68.0	1.84		Y
30	8.3	----	1.86		Y
31	8.2	64.0	1.84		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: July 2024
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature:

Date: July 31, 2024 *Completed once day was done*

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2