



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.2	----	1.68		Y
2	8.5	56.0	1.76		Y
3	8.2	----	1.72		Y
4	8.5	55.0	2.20		Y
5	----	----	----		----
6	----	----	----		----
7	8.3	60.0	1.70		Y
8	8.4	----	1.76		Y
9	8.4	58.0	1.45		Y
10	8.4	----	1.49		Y
11	8.3	57.0	1.59		Y
12	----	----	----		----
13	----	----	----		----
14	8.2	53.0	1.61		Y
15	8.3	----	1.56		Y
16	8.1	65.0	1.56		Y
17	8.2	----	1.32		Y
18	8.2	64.0	1.39		Y
19	----	----	----		----
20	----	----	----		----
21	7.9	56.0	1.71		Y
22	8.0	----	1.76		Y
23	8.0	57.0	1.74		Y
24	8.2	----	1.80		Y
25	8.2	63.0	1.88		Y
26	----	----	----		----
27	----	----	----		----
28	8.0	57.0	1.40		Y
29	8.0	----	1.44		Y
30	8.1	58.0	1.55		Y
31	8.2	----	1.64		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: October 2024
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>(_____)</i>

Print Name: Ryan A. Sherman

Signature:

Date: November 1, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2