



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.3	60.0	1.74		Y
2	----	----	----		----
3	----	----	----		----
4	8.5	59.0	1.36		Y
5	8.4	----	1.34		Y
6	8.4	58.0	1.44		Y
7	8.5	----	1.49		Y
8	8.0	52.0	2.20		Y
9	----	----	----		----
10	----	----	----		----
11	8.2	51.0	1.31		Y
12	8.3	----	1.32		Y
13	8.1	38.0	1.30		Y
14	8.0	----	1.30		Y
15	8.0	36.0	1.46		Y
16	----	----	----		----
17	----	----	----		----
18	8.2	40.0	1.59		Y
19	8.2	----	1.66		Y
20	8.2	40.0	1.73		Y
21	7.9	----	2.32		Y
22	8.0	40.0	2.40		Y
23	----	----	----		----
24	----	----	----		----
25	8.0	40.0	2.38		Y
26	7.9	----	1.76		Y
27	8.6	40.0	1.84		Y
28	8.6	----	1.87		Y
29	8.6	40.0	1.88		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: November 2024
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature:

Date: December 2, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2