



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	----	----	----		----
2	8.1	50.0	1.79		Y
3	8.3	----	1.84		Y
4	8.0	51.0	2.58		Y
5	8.4	----	2.61		Y
6	8.1	50.0	2.49		Y
7	----	----	----		----
8	----	----	----		----
9	8.1	50.0	1.97		Y
10	8.0	----	1.95		Y
11	7.9	50.0	1.91		Y
12	7.9	----	1.90		Y
13	7.9	50.0	1.96		Y
14	----	----	----		----
15	----	----	----		----
16	7.8	50.0	1.96		Y
17	7.9	----	1.98		Y
18	7.8	35.0	1.77		Y
19	7.8	----	1.84		Y
20	7.9	35.0	2.20		Y
21	----	----	----		----
22	----	----	----		----
23	8.0	34.0	1.71		Y
24	8.0	----	1.76		Y
25	----	----	----		----
26	8.1	37.0	1.86		Y
27	7.9	37.0	1.69		Y
28	----	----	----		----
29	----	----	----		----
30	8.0	47.0	1.65		Y
31	8.1	----	1.76		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** December 2024  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	( )

**Print Name:** \_\_\_\_\_

**Signature:**

**Date:** January 2, 2025

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
 Page 1 of 2