

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	-----	-----	-----		-----
2	-----	-----	-----		-----
3	8.4	39.0	2.19		Y
4	8.3	-----	1.70		Y
5	8.1	47.0	1.60		Y
6	8.1	-----	1.54		Y
7	8.2	47.0	1.59		Y
8	-----	-----	-----		-----
9	-----	-----	-----		-----
10	8.2	48.0	1.65		Y
11	8.2	-----	1.73		Y
12	8.2	49.0	1.76		Y
13	8.2	-----	1.81		Y
14	8.3	48.0	1.90		Y
15	-----	-----	-----		-----
16	-----	-----	-----		-----
17	-----	-----	-----		-----
18	8.4	55.0	1.99		Y
19	8.3	-----	1.76		Y
20	8.3	50.0	1.82		Y
21	8.3	30.0	1.84		Y
22	8.2	-----	1.89		Y
23	8.3	36.0	1.96		Y
24	8.2	-----	2.12		Y
25	8.2	38.0	1.96		Y
26	8.5	-----	1.73		Y
27	8.9	36.0	1.35		Y
28	8.5	43.0	2.20		Y
29	-----	-----	-----		-----
30	-----	-----	-----		-----
31	8.6	35.0	1.35		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: March 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name:

Signature:

Date:

Ryan A. Sherman

[Signature]

April 1, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>