



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.2	----	1.40		Y
2	8.4	45.0	1.56		Y
3	----	----	----		----
4	----	----	----		----
5	8.4	40.0	1.31		Y
6	8.6	----	1.37		Y
7	8.6	43.0	1.39		Y
8	8.4	----	2.20		Y
9	8.9	50.0	2.07		Y
10	----	----	----		----
11	----	----	----		----
12	8.4	50.0	1.96		Y
13	8.5	----	2.20		Y
14	8.8	50.0	2.20		Y
15	8.9	----	2.20		Y
16	8.9	50.0	2.07		Y
17	----	----	----		----
18	----	----	----		----
19	8.8	48.0	2.14		Y
20	8.7	----	2.09		Y
21	8.9	59.0	2.03		Y
22	8.6	----	2.11		Y
23	8.3	58.0	1.35		Y
24	----	----	----		----
25	----	----	----		----
26	8.3	58.0	1.47		Y
27	8.4	----	1.30		Y
28	----	----	----		----
29	8.4	----	1.32		Y
30	8.8	42.0	1.31		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: May 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: Ryan A. Sherman

Date: June 3, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>