

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.7	54.0	1.32		Y
3	8.7	----	1.31		Y
4	8.9	55.0	1.36		Y
5	8.8	----	2.20		Y
6	8.8	53.0	1.32		Y
7	----	----	----		----
8	----	----	----		----
9	8.7	52.0	1.36		Y
10	8.7	----	1.45		Y
11	8.6	52.0	1.44		Y
12	8.7	----	1.33		Y
13	8.7	56.0	1.39		Y
14	----	----	----		----
15	----	----	----		----
16	8.7	55.0	1.33		Y
17	8.7	----	1.31		Y
18	7.7	48.0	1.35		Y
19	7.9	----	1.33		Y
20	8.0	47.0	1.42		Y
21	----	----	----		----
22	----	----	----		----
23	8.1	52.0	1.39		Y
24	8.2	----	1.44		Y
25	8.2	44.0	1.40		Y
26	8.4	----	2.20		Y
27	8.4	45.0	2.20		Y
28	----	----	----		----
29	----	----	----		----
30	8.2	52.0	1.37		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: June 2025

Month/Year

Number of excursions during this month : 0

*(Count the number of days when any WQP was less
than the minimum required)*

Total excursions during the previous 5 months: _____

*(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)*

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: [Signature]

Date: July 1, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>