

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.2	----	2.20		Y
2	8.4	49.0	1.54		Y
3	8.2	----	1.43		Y
4	8.2	50.0	1.46		Y
5	----	----	----		----
6	8.4	50.0	1.54		Y
7	8.5	----	1.88		Y
8	8.6	52.0	1.74		Y
9	8.5	----	1.84		Y
10	8.6	61.0	1.34		Y
11	8.7	----	1.38		Y
12	----	----	----		----
13	----	----	----		----
14	8.6	57.0	2.20		Y
15	8.5	----	2.07		Y
16	8.6	58.0	2.12		Y
17	8.1	----	1.43		Y
18	8.2	59.0	1.52		Y
19	----	----	----		----
20	----	----	----		----
21	8.3	51.0	1.47		Y
22	8.4	----	1.47		Y
23	8.4	52.0	1.51		Y
24	8.5	----	1.61		Y
25	8.5	53.0	1.66		Y
26	----	----	----		----
27	----	----	----		----
28	8.4	50.0	1.62		Y
29	8.4	----	1.55		Y
30	8.5	51.0	1.59		Y
31	8.6	----	1.64		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: July 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: RYAN A. SHERMAN

Signature: 

Date: August 1, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>