



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.5	56.0	1.61		Y
2	----	----	----		----
3	----	----	----		----
4	8.6	54.0	1.68		Y
5	8.5	53.0	1.69		Y
6	8.7	52.0	2.20		Y
7	8.6	----	2.20		Y
8	8.5	51.0	2.20		Y
9	----	----	----		----
10	----	----	----		----
11	8.4	54.0	1.98		Y
12	8.7	50.0	1.86		Y
13	8.8	54.0	1.84		Y
14	8.8	----	1.79		Y
15	9.0	57.0	1.68		Y
16	----	----	----		----
17	----	----	----		----
18	8.5	58.0	1.80		Y
19	8.6	----	2.20		Y
20	8.6	59.0	2.17		Y
21	8.6	----	2.09		Y
22	8.5	54.0	2.01		Y
23	----	----	----		----
24	----	----	----		----
25	8.6	69.0	1.75		Y
26	8.6	----	1.79		Y
27	8.8	59.0	1.79		Y
28	8.7	----	2.20		Y
29	8.6	59.0	2.12		Y
30	----	----	----		----
31	8.6	59.0	2.20		Y
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: August 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name:

Signature:

Date:

Ryan A. Sherman

Ryan A. Sherman

September 1, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>