

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	54.0	1.32		Y
2	8.3	-----	1.31		Y
3	7.9	50.0	1.32		Y
4	-----	-----	-----		-----
5	-----	-----	-----		-----
6	8.2	49.0	1.50		Y
7	8.2	-----	1.54		Y
8	8.1	54.0	1.39		Y
9	8.3	-----	1.30		Y
10	8.2	45.0	1.32		Y
11	-----	-----	-----		-----
12	-----	-----	-----		-----
13	8.2	45.0	1.33		Y
14	8.3	-----	1.31		Y
15	8.2	52.0	1.35		Y
16	8.3	-----	1.63		Y
17	8.2	45.0	1.33		Y
18	-----	-----	-----		-----
19	-----	-----	-----		-----
20	8.2	49.0	1.30		Y
21	8.0	-----	1.31		Y
22	8.0	47.0	1.32		Y
23	8.3	-----	1.33		Y
24	8.3	44.0	1.32		Y
25	-----	-----	-----		-----
26	-----	-----	-----		-----
27	7.8	47.0	1.32		Y
28	8.0	-----	1.30		Y
29	8.2	44.0	1.38		Y
30	8.1	-----	1.44		Y
31	8.3	35.0	1.50		Y
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: Oct 2025

Month/Year

Number of excursions during this month : 0

*(Count the number of days when any WQP was less
than the minimum required)*

Total excursions during the previous 5 months: _____

*(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)*

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: Ryan A. Sherman

Date: November 6, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>