

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	----	----	----		----
3	8.2	45.0	1.33		Y
4	8.0	35.0	1.53		Y
5	8.0	38.0	1.31		Y
6	8.3	37.0	1.37		Y
7	8.3	37.0	1.49		Y
8	----	----	----		----
9	----	----	----		----
10	8.3	37.0	1.40		Y
11	8.0	----	1.41		Y
12	8.1	44.0	1.30		Y
13	8.2	----	1.32		Y
14	8.2	30.0	1.33		Y
15	----	----	----		----
16	----	----	----		----
17	8.3	35.0	1.30		Y
18	8.3	----	1.33		Y
19	8.3	37.0	1.36		Y
20	8.5	----	1.44		Y
21	8.6	36.0	2.20		Y
22	----	----	----		----
23	----	----	----		----
24	8.3	36.0	2.20		Y
25	8.3	----	2.20		Y
26	8.3	43.0	2.20		Y
27	8.2	40.0	1.47		Y
28	8.3	40.0	1.42		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have
minimums been
met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: November 2025

Month/Year

Number of excursions during this month : 0

*(Count the number of days when any WQP was less
than the minimum required)*

Total excursions during the previous 5 months: _____

*(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)*

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name:

Signature:

Date:

Ryan A. Sherman

[Signature]

December 2, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>