



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.0	----	1.60		Y
2	----	----	----		----
3	8.1	37.0	2.20		Y
4	8.0	----	1.73		Y
5	7.9	43.0	1.60		Y
6	8.0	----	1.73		Y
7	8.1	40.0	1.69		Y
8	7.8	----	1.72		Y
9	8.0	43.0	1.79		Y
10	----	----	----		----
11	----	----	----		----
12	8.2	41.0	1.69		Y
13	8.3	----	1.76		Y
14	8.2	40.0	1.80		Y
15	8.0	----	1.72		Y
16	7.8	39.0	1.76		Y
17	----	----	----		----
18	----	----	----		----
19	7.9	40.0	1.84		Y
20	7.9	----	1.87		Y
21	8.0	45.0	1.76		Y
22	8.2	----	2.20		Y
23	8.3	46.0	2.20		Y
24	----	----	----		----
25	----	----	----		----
26	8.4	51.0	1.75		Y
27	8.1	----	1.56		Y
28	8.2	50.0	1.59		Y
29	8.2	----	1.66		Y
30	8.2	50.0	1.72		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: January 2026
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature:

Date: February 2, 2026

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2