



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.0	40.0	1.40		Y
3	8.5	----	1.54		Y
4	8.6	44.0	1.69		Y
5	8.5	----	1.72		Y
6	8.3	41.0	1.68		Y
7	----	----	----		----
8	----	----	----		----
9	8.3	40.0	1.76		Y
10	8.5	----	1.98		Y
11	8.9	54.0	1.46		Y
12	8.7	----	1.55		Y
13	8.1	36.0	1.52		Y
14	----	----	----		----
15	----	----	----		----
16	8.1	43.0	1.53		Y
17	8.1	----	1.59		Y
18	8.1	50.0	1.55		Y
19	8.2	----	1.62		Y
20	8.2	50.0	1.66		Y
21	----	----	----		----
22	8.3	51.0	1.89		Y
23	8.4	----	1.92		Y
24	8.4	52.0	1.86		Y
25	8.4	----	1.83		Y
26	8.4	49.0	1.64		Y
27	8.3	----	1.69		Y
28	----	----	----		----
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: February 2026
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>()</i>

Print Name: Ryan A. Sherman

Signature:

Date: March 2, 2026